

SITE PLAN
SCALE 1:200

LEGEND	
	DISTRIBUTION BOARD
	2P ISOLATOR MOUNTED 2500mm A.F.F.L
	CABLE

NOTE:

1. CABLE TO BE BURIED 700mm BELOW GROUND WITHIN 75mm SLEEVE.
2. INSTALL 32mm² BOSAL CONDUIT COMPLETE WITH NECESSARY ACCESSORIES.

TYPICAL UNDERGROUND SLEEVE DETAIL

SCALE 1: 20

ISSUED FOR TENDER

No.	DATE	AMENDMENT	D.P.W.

Copyright vests in the
Department of Public Works

as-built drawings

certified as-built drawings as per Centralised Drawing Archive AS-BUILT DRAWING REQUIREMENTS

name: _____

date: _____

professional registration no.: _____

DBSA

Sivpro Engineering Joint Venture

education
Department:
Education
PROVINCE OF KWAZULU-NATAL

discipline: ELECTRICAL

service:

drawing title

KZN D.O.E. INFRASTRUCTURE DEVELOPMENT AND MAINTENANCE PROGRAM

INKONKONI PRIMARY SCHOOL

SITE PLAN
RETICULATION LAYOUT

ref.no.	000000	designed	000000
scale	1:200	drawn	LM
date	JAN 2023	checked	MM

drawing number: D19001-500-0008

REV: 00