












Type		Description	Installation	Lamps		Qty	Location	Comments
				Type	Colour			
A1/e		LED Linear vapour proof fitting (IP65), with poly carbonate UV protected opal diffuser and stainless clips. (130 - 160 lumens per watt and CRI 80+). 1 hour self contained emergency version where indicated. Complete with 5 year warantee	Surface on soffit	40-50W LED	4000K		Basement Parking	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations / Beka
A2/e		600x600 Dimmable LED panel with white alumimium trim. Back lit with a 4mm opal diffuser and PMMA light guide CRI 80+, UGR =19, 120-130 lumens per watt complete with 6amp plug top and 3m cordset. 1 hour battery back up where indicated with 'e'. Complete with 5 year warantee	Recessed in ceiling	35-40W LED	4000K		Boardrooms	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations
B1/e		600x600 LED panel with white alumimium trim. Back lit with a 4mm opal diffuser and PMMA light guide CRI 80+, UGR =19, 120-130 lumens per watt complete with 6amp plug top and 3m cordset. 1 hour battery back up where indicated with 'e'. Complete with 5 year warantee	Recessed in ceiling	35-40W LED	4000K		Offices / Passges	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations
C		Pendent Light fitting	Surface / Suspended	10W E27 LED	4000K		Ablutions	Radiant PB05: Pendant 240V Shute
D		Ceiling mounted emergnecy exit signage. Complete with 2 hour self contained, maintained emergency with separate red/green indicator lights and test button. Complete with 5 year warantee	Ceiling Mounted	8W LED	4000K		Fire Escapes	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations

Notes


Samples of all luminaires are to be presented for approval before orders are placed.
Quantities are to be confirmed by contractor
Lamps to be Osram ,Phillips or equal and approved. Control gear to be Osram, Phillips, Tridonic, V&S or equal and approved . Full details to be submitted with sample.
All light fittings to have a 5 year guarantee, light fittings to have LM79, LM80 and TM21 test reports. Fittings to comply with L70/B50.




				ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:	 GOVERNMENT PRINTING WORKS - REFURBISHMENT Luminaire Schedule
				MK	VT	NOV'17	MK	A4		
B	General Revision	MK	31/07/20	MK	PROJ No.:	DWG No	REV	SCALE		
A	General Revision	VT	25/02/20	MK	17052	601	B	nts		
0	Original Issue	VT	22/02/18	AM						
REV	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	17052_601	SHEET:	1 of 3		

Type		Description	Installation	Lamps		Qty	Location	Comments
				Type	Colour			
E1/e		Die-cast aluminium LED downlighter with 120-140 lumens per watt (CRI 80+), complete with 3m cordset and 6amp plug top. 1 hour emergency battery back up where indicated with "e". Complete with 5 year warantee	Recessed in ceiling	10-12W LED	4000K		Ablutions	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations
E2/e		Die-cast aluminium dimmable LED downlighter with 120-140 lumens per watt (CRI 80+), complete with 3m cordset and 6amp plug top. 1 hour emergency battery back up where indicated with "e". Complete with 5 year warantee.	Recessed in ceiling	18-25W LED	4000K		Passages / Boardrooms	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations
F1/e		Surface mounted bulkhead fitting. (1 hour self contained emergency version where indicated. Supplied complete with 3m cordset and 5A plugtop.)	Surface Mounted	17W LED	4000K		Stairways	Beka Series 30 or equal and approved
G		Recessed adjustable downlight. Supplied complete with 3m cordset and 5A plugtop.	Recessed in plasterboard ceiling	GU10, 7.5 W LED dimmable (Phillips/Osram Lamp)	4000K		Lift Lobby/ Boardrooms	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations
H		IP65 LED Flood light	Surface Mounted	70W LED	4000K		External Parking	Philips Smart Bright LED Floor or equal and approved

Notes


Samples of all luminaires are to be presented for approval before orders are placed.
Quantities are to be confirmed by contractor
Lamps to be Osram ,Phillips or equal and approved. Control gear to be Osram, Phillips, Tridonic, V&S or equal and approved . Full details to be submitted with sample.
All light fittings to have a 5 year guarantee, light fittings to have LM79, LM80 and TM21 test reports. Fittings to comply with L70/B50.

					ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE: GOVERNMENT PRINTING WORKS - REFURBISHMENT Luminaire Schedule  Solutions For The Built Environment
					MK	VT	NOV'17	MK	A4	
B	General Revision	MK	31/07/20	MK	PROJ No.:		DWG No	REV	SCALE	
A	General Revision	VT	25/02/20	MK	17052		601	B	nts	
0	Original Issue	VT	22/02/18	AM						
REV	DESCRIPTION	BY	DATE	CHKD	FILE NAME: 17052_601			SHEET: 2 of 3		

Type		Description	Installation	Lamps		Qty	Location	Comments
				Type	Colour			
J/Je		900mm aluminium linear surface profile, matt silver with frosted diffuser, complete with 3m cordset and 6A plugtop. 1 hour self contained emergency version where indicated. (110 - 130 lumens per watt)	Surface Mounted	LED 24 W/m	400K		Staircases	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations / Regent
T1/e		1200mm aluminium linear recessed luminaire complete with 33mm wide frosted diffuser and matte silver ceiling trim. Supplied complete with 3m cordset and 6A plugtop. 1 hour self contained emergency version where indicated. (110 - 130 lumens per watt)	Recessed in gypsum ceiling.	LED, 24 W/m	4000K		Foyers	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations / Regent
T2/e		3000mm aluminium linear recessed luminaire complete with 33mm wide frosted diffuser and matte silver ceiling trim. Supplied complete with 3m cordset and 6A plugtop. 1 hour self contained emergency version where indicated. (110 - 130 lumens per watt)	Recessed in gypsum ceiling.	LED, 24 W/m	4000K		Foyers	Supplied by Province Lighting / ETAP / Performace Lighting / Lighting Innovations / Regent

Notes

Samples of all luminaires are to be presented for approval before orders are placed.
Quantities are to be confirmed by contractor
Lamps to be Osram ,Phillips or equal and approved. Control gear to be Osram, Phillips, Tridonic, V&S or equal and approved . Full details to be submitted with sample.
All light fittings to have a 5 year guarantee, light fittings to have LM79, LM80 and TM21 test reports. Fittings to comply with L70/B50.

					ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:	 LDM <i>Solutions For The Built Environment</i>
					MK	VT	NOV'17	MK	A4	GOVERNMENT PRINTING WORKS - REFURBISHMENT	
B	General Revision	MK	31/07/20	MK	PROJ No.:		DWG No	REV	SCALE	Luminaire Schedule	
A	General Revision	VT	25/02/20	MK	17052		601	B	nts		
0	Original Issue	VT	22/02/18	AM							
REV	DESCRIPTION	BY	DATE	CHKD	FILE NAME: 17052_601			SHEET: 3 of 3			