



BLOCK E CLASSROOM LIGHTING LAYOUT
SCALE 1:100



BLOCK G ABLUTION LIGHTING LAYOUT
SCALE 1:100



BLOCK F CLASSROOM LIGHTING LAYOUT
SCALE 1:100



BLOCK H ABLUTION LIGHTING LAYOUT
SCALE 1:100

LIGHTING NOTES:

NOTE 1 :CONTROL OF LIGHTING

EXTERNAL LIGHTING CONTROL TO BE ON A DAY/NIGHT SWITCH.

NOTE 2 :24 HOUR LIGHTING:

24 HOUR LIGHTING NOT TO BE SWITCHED THROUGH CONTRACTOR. FITTING MARKED 'E' TO HAVE 20% MAINTAINED BATTERY PACK FITTED ONLY FOR MINIMUM OF 1hr.

NOTE 3 :STEEL TRUNKING:

STEEL TRUNKING OF SUITABLE SIZE COMPLETE WITH PVC COVER AND ACCESSORIES FOR LIGHTING AND POWER CIRCUITS. WIRING IN TRUNKING NOT TO EXCEED 40% CAPACITY. 5 AMP SOCKETS TO BE MOUNTED IN TRUNKING OR ON TRUNKING FOR PLUGGING IN OF LUMINAIRES.

DRAWING STATUS:

FOR INFORMATION

FUNDER:



IMPLEMENTING AGENT:



PRINCIPAL AGENT:



No.7 Bush Shrike Close
Victoria Country Club Estate
170 Peter Brown Drive
Montrose, Pietermaritzburg
3201

Tel :033 347 7900

cell:maritzburg@mariswe.com

ARCHITECT:



NO 13 Backway Road
Methuen
TEL: 047 532 4762
FAX: 047 521 3302
086 580 3158
email: info@spaceth.com

ENGINEER.



6, Scherwitz Road | Beria | East London
Tel: +27 43 722 3353 Fax: +27 86 554 6496
info@karosolutions.co.za

PROJECT:

AMABUYE SECONDARY SCHOOL,
DUBE TRIBAL AUTHORITY,
ESIKHAWINI, 3887, KWAZULU
NATAL.

EMIS No: 500101306

TITLE:

BLOCK A, B, C & D
LIGHTING LAYOUT

© COPYRIGHT RESERVED

The content of this document is privileged and confidential and may not be disclosed or reproduced without the express authorisation of the author, being "KARO SOLUTIONS"