



### TYPICAL UNDERGROUND SLEEVE DETAIL

SCALE 1: 20

**NOTE:**

1. CABLE TO BE BURIED 700mm BELOW GROUND WITHIN 75mm SLEEVE AND 100mm X 100mm CONCRETE.
2. INSTALL 32mm<sup>2</sup> BOSAL CONDUIT COMPLETE WITH NECESSARY ACCESSORIES.

Stamp by Plans Approval Committee

**Stamped by Plans Approval Committee**