



1. The installation is to comply in full to the latest SANS 10142 standards and specifications.
2. All SOU must be installed in accordance with new gazetted regulations and in accordance to SANS 0142 and Department of Education regulations and specifications.
3. The electrical installation shall be in accordance to the standards and regulations prescribed by SANS for the installation of electrical services.
4. All electrical equipment to be SABS approved.
5. It is the responsibility of the installation contractor to ensure all and every aspect of the electrical installation is in accordance to required standards and regulations prescribed by South African standards for the wiring of premises and in accordance to the Department of Education, Province of KwaZulu Natal specifications and regulations.
6. Each sub distribution board and Telkom distribution tray to be earthed.

	1500mm OPN CHAN. FLUO. FITTING EQUAL TO LASCON RITA, FITTED WITH 2x OSRAM SBAU-EM 22.5W/840 1500mm 3600 LUMENS
	LIGHT SWITCH
	ROUND LED BULKHEAD WITH DIE-CAST ALUMINIUM BASE [WHITE] AND OPAL NIGHT-IMPACT ACRYLIC DIFFUSER. EQUAL TO BREA 3D SERIES BULKHEAD 9WLED 1470 LUMENS - WALL MOUNTED.
	16A 3-PIN & NEW RSA EURO
	SINGLE PHASE ISOLATOR
	DISTRIBUTION BOARD
	DAY/NIGHT SENSOR



-	ISSUED FOR TENDER:								14.09.2022
REVISIONS									
CLIENT									
PROJECT		NECKEYA PRIMARY SCHOOL EMIS 500342213 KING CETHSWAYO DISTRICT UMLAZALI LOCAL MUNICIPALITY							
DESCRIPTION									
BLOCK A ELECTRICAL SERVICES									
STATUS		INFORMATION				CONSTRUCTION			
		TENDER			X	AS BUILT			
DRAWING NO		SCALE	PAGE SIZE	DRAWN	APPROVED BY				REV
2110_02		1:100	A1	CD	Home & Sumarno Craig Westo Registration no: P-19304 Regulation council: KCSA Registration ref: 25005DE				-
 E - CONSULTING Electrical • Electronic and • Energy management services									
UNIT 8 WOODLANDS HOUSE 17A WOODLANDS ROAD WOODSTOCK 16001 TEL : 021 447 3832 email: admin@econsulting.co.za									