TENDER NO. RFP031/2024 APPOINTMENT OF A CONTRACTOR FOR THE INSTALLATION OF TEMPORARY FACILITIES AND BULK SERVICES AT ENOCH MAMBA SENIOR SECONDARY SCHOOL ON BEHALF OF EASTERN CAPE DEPARTMENT OF EDUCATION (ECDOE)



QUESTIONS AND ANSWERS NO. 1

No.	Query	Response
1	Elevated pressed steel tank on the projects, however, there seems to be some discrepancies in the documents with regards to the tanks size and height as listed below. BOQ's: 261kL Tank on a 10m Tower Drawing: J15-029-CE-DET-011; 136kL Tank on 15m Tower Drawing: J15-029-CE-S3-001; 32kL Tank (No Height Provided)	The size of the tank is 261kL Tank on a 10m Tower as per the BoQ. Please note that the layout - J15-029-CE-DET-011 depicts a typical tank stand detail and makes no reference to the tank size. The tank size as per J15-029-CE-S3-001 is based on Phase one planning of the project. The specification as per the BoQ is governing for the entire project in this case.
2	Please provide clear borehole drawings, the specialist contractor cannot use this one for quotation	Please note the Pump house has been depicted under drawing: J15 029-CE-DET-006. A provisional sum has been allocated on the BoQ for the pump house under Section No.4. Section 2, Bill 5 details the items that are to be priced by the prospective tenderers for the borehole. The items descriptions are adequate for pricing purposes. Final borehole equipping, testing, and commissioning information/ processes will be concluded following the sighting, drilling, and yield testing of the borehole. There are no other borehole drawings to be made available to the tenderers
3	The drawings given for prefabricated blocks under decanting, does not correspond with the Bill of quantities.	What is critical to note is that the drawings are intended to be as generic as possible not to give advantage or preference to any supplier and their designs. They provide guidance and perimeters especially on specialist/supply items that the successful tenderer will be procuring at their behest.
4	Please provide drawings for the administration block.	Please refer to addendum no.2 for the administration block drawings
5	Should we price according to the Bill of quantities or the drawings?	Pricing should be done according to the Bill, as that is the basis on which prospective tenderers will be evaluated.